



Community Development  
Development Services Division  
501 SW Madison Avenue  
P.O. Box 1083  
Corvallis, OR 97339-1083  
(541) 757-6929  
TTY (541) 757-6477

January 21, 1999

Scott Lepman  
815 NW Elm  
Albany, OR 97321

Re: Engineered Fill Submittal Response - Permit #EXC98-00010

This is in response to your submittal of compaction observation reports submitted by Braun Intertec on January 12, 1999.

This submittal does not meet minimum requirements for certification of fill. The City requirements and the building code states in part as follows.

**"The applicant shall identify each specific lot in the area covered by the permit application as to whether the proposed grading activity will impact an identified future building pad, and for lots which will have building pads affected, provide a pad certification report, with appropriate support documentation, stamped by a registered professional civil, soils, or geotechnical engineer or engineering geologist, indicating that the building pad meets the requirements of the City Building Code, including the above-referenced Appendix Chapter 33 of the OSSC."**

Please submit to Development Services the appropriate certification as stated above. No building permits shall be approved until these actions have been completed.

If you have any questions, please feel free to call me.

F. Gale Farley  
Site Engineering Review Specialist

C: Eric Sandoval, Plans Examiner  
Mike Fegles, Assistant Building Official