



Community Development
Development Services Division
501 SW Madison Avenue
P.O. Box 1083
Corvallis, OR 97339-1083
(541) 766-6929
TTY (541) 766-6477

January 28, 2002

Roger A. Superneau, Architect
Ankrom Moisan & Associates
6720 SW Macadam
Portland, OR 97219

Ref: Elevator Smoke Enclosure Doors, Corvallis Caring Place, 750 NW 23rd Street, Corvallis, Oregon. Permit Number: BLD00-01604.

In response to your letter dated January 17, 2002, this letter is to confirm that your assumption of OSSC Section 711.3 is correct. When two adjacent stories communicate with each other, penetrations at the second level would not be required to be enclosed or protected.

Your request to eliminate the elevator smoke enclosure doors has been approved.

Should you have any questions, please feel free to contact me at 541-766-6929.

Respectfully,

Dick Huff
Plans Examiner

c: Mike Fegles, Assistant Building Official
Steve Freiling, Building Inspector