

*Project
File*
MSS INC
ENGINEERING CONSULTANTS
BUILDING CONTRACTORS
PLANNERS


May 22, 2001
James Cauthorn
4790 NW Walnut Blvd
Corvallis, OR 97330

Re: Compaction of Fill on your site on Ponderosa Ave.

Dear James,

Providing you have a fill and grading permit for this site and have placed erosion control fences (which I have observed are in place), you are not required to create a structural fill which is certified by a geotechnical testing report. You can compact the material as it is delivered to the site by means of a small dozer. This will create adequate compaction to stabilize the material, but is generally considered inadequate to prevent long term settlement of the filled earth mass.

Sincerely



John Seaders PE



EXPIRES 6/30/2002