



NOTES:

1. CONCRETE SHALL ATTAIN A MIN. COMPRESSIVE STRENGTH OF 3,000 P.S.I. IN 28 DAYS.
2. USE BEEHIVE GRATE WHEN SPECIFIED.
3. DRILL $\frac{3}{8}$ " \varnothing HOLE FOR TRACER WIRE. EXTEND TRACER WIRE INTO INLET STRUCTURE AND SEAL WITH NON SHRINK GROUT. TYP FOR ALL PIPE RUNS ENTERING STRUCTURE. LEAVE ENOUGH FREE WIRE TO EXTEND 18" ABOVE GRATE. SEE STANDARD DETAIL NO. 201 FOR TRACER WIRE SPECIFICATIONS.

CITY OF CORVALLIS

ENGINEERING DIVISION

**AREA DRAINAGE BASIN
OR FIELD INLET**

DATE: JANUARY 2020

SCALE: NONE

STANDARD DETAIL No.

APPROVED: *BAJ*

208A