



**TOP SECTION**

**DIRECT BURY FIBERGLASS POLE**

**NOTES:**

1. ALL DIRECT BURY FIBERGLASS POLES SHALL BE INSTALLED PER SECTION II.10. OF THE STANDARD CONSTRUCTION SPECIFICATIONS.
2. POLE INSTALLATIONS AND MATERIALS SHALL MEET ALL MANUFACTURER'S REQUIREMENTS AND RECOMMENDATIONS.
3. ALL JUNCTION BOXES SHALL BE PLACED 2' ON CENTER FROM BACK OF WALK WHEN A SIDEWALK IS PRESENT.
4. IN PLANTER STRIP AREAS THAT DO NOT ALLOW FOR THE (MIN) CLEARANCES WITH CURB AND SIDEWALK, POLE LOCATION SHALL BE APPROVED BY ENGINEER.
5. ALL HARDWARE AND FASTENERS SHALL BE HOT DIPPED GALVANIZED OR STAINLESS STEEL.
6. ALL BONDING AND WIRING SHALL COLPLY WITH THE STANDARD SPECIFICATIONS AND ALL APPLICABLE ELECTRIC CODES.

<b>CITY OF CORVALLIS</b>		
ENGINEERING DIVISION		
<b>LUMINAIRE INSTALLATION ON FIBERGLASS POLE</b>		
DATE: JANUARY 2020	SCALE: NONE	STANDARD DETAIL No.
APPROVED: <i>EB</i>		<b>404</b>